

Subject :- Providing and fixing basement mechanical parklift/combilift car parking with horizontal and wider platforms, for Construction of Commercial Complex in Sector No. 24, SDC Nigadi, PCNTDA, Pune-411044
Interested manufacturers / Contractors / Suppliers are requested to submit sealed quotation of following items on or before 3.00 PM on 06/06/2019.

S.No.	Description of Item	Estimated Qty	Unit	Rate	Amount																																																
1	Providing and fixing basement mechanical parklift/combilift car and bike parking with horizontal and wider platforms, low maintenance cost, high level operational and functional safety equivalent to EN norms. The installation is designed to operate between +5° and +40°C and atmospheric Humidity: 50% at +40°C. Standard and comfort to be considered as follows-	21 Cars	Number																																																		
	<table border="1"> <thead> <tr> <th>Standard type</th> <th>Parklift</th> <th>Parklift</th> <th>Parklift</th> </tr> <tr> <td></td> <td>411/5-155</td> <td>411/5-165</td> <td>411/5-175</td> </tr> </thead> <tbody> <tr> <td>Height h 1* single unit</td> <td>320</td> <td>330</td> <td>340</td> </tr> <tr> <td>Car height lower level</td> <td>150</td> <td>160</td> <td>170</td> </tr> <tr> <td>Car height upper level*</td> <td>150</td> <td>150</td> <td>150</td> </tr> </tbody> </table>	Standard type	Parklift	Parklift	Parklift		411/5-155	411/5-165	411/5-175	Height h 1* single unit	320	330	340	Car height lower level	150	160	170	Car height upper level*	150	150	150	120 Bikes	Number																														
Standard type	Parklift	Parklift	Parklift																																																		
	411/5-155	411/5-165	411/5-175																																																		
Height h 1* single unit	320	330	340																																																		
Car height lower level	150	160	170																																																		
Car height upper level*	150	150	150																																																		
	<table border="1"> <thead> <tr> <th>Comfort type</th> <th>Parklift</th> <th>Parklift</th> <th>Parklift</th> </tr> <tr> <td></td> <td>411/5-185</td> <td>411/5-195</td> <td>411/5-205</td> </tr> </thead> <tbody> <tr> <td>Height h 1* single unit</td> <td>350</td> <td>360</td> <td>370</td> </tr> <tr> <td>Car height lower level</td> <td>180</td> <td>190</td> <td>200</td> </tr> <tr> <td>Car height upper level*</td> <td>150</td> <td>150</td> <td>150</td> </tr> </tbody> </table>	Comfort type	Parklift	Parklift	Parklift		411/5-185	411/5-195	411/5-205	Height h 1* single unit	350	360	370	Car height lower level	180	190	200	Car height upper level*	150	150	150																																
Comfort type	Parklift	Parklift	Parklift																																																		
	411/5-185	411/5-195	411/5-205																																																		
Height h 1* single unit	350	360	370																																																		
Car height lower level	180	190	200																																																		
Car height upper level*	150	150	150																																																		
	Electrical data to be considered is as follows-																																																				
	<table border="1"> <thead> <tr> <th>Item</th> <th>Performance</th> <th>Quantity</th> <th>Designation</th> <th>Position</th> <th>Frequency</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>by customer</td> <td>1 unit</td> <td>electric meter</td> <td>in the feed cable</td> <td></td> </tr> <tr> <td>2</td> <td>by customer</td> <td>1 unit</td> <td>fuse or automatic circuit breaker 3x16A slow blow acc. to DIN VDE 0100 p. 430</td> <td>in the feed cable</td> <td>1 per power pack</td> </tr> <tr> <td>3</td> <td>by customer</td> <td>as locally required</td> <td>acc. to local power supply regulations 3 Ph + N + PE*</td> <td>feed cable to main switch</td> <td>1 per power pack</td> </tr> <tr> <td>4</td> <td>by customer</td> <td>each 10 m</td> <td>equipotential bonding safety lead-out connection</td> <td>corner pit floor/rearwall</td> <td></td> </tr> <tr> <td>5</td> <td>by customer</td> <td>1 unit</td> <td>equipotential bonding safety compliant to the DIN EN 60204 standard</td> <td>from the lead-out connection to the Parklift system</td> <td>1 per Parklift</td> </tr> <tr> <td>6</td> <td>by customer</td> <td>1 unit</td> <td>marked main switch, lockable to prevent unauthorized switching on</td> <td>above operating device</td> <td>1 per power pack</td> </tr> <tr> <td>7</td> <td>by customer</td> <td>10 m</td> <td>PVC control cable with marked strands and protective conductor 5 x 1,5²</td> <td>from main switch to hydraulic power pack</td> <td>1 per power pack</td> </tr> </tbody> </table>	Item	Performance	Quantity	Designation	Position	Frequency	1	by customer	1 unit	electric meter	in the feed cable		2	by customer	1 unit	fuse or automatic circuit breaker 3x16A slow blow acc. to DIN VDE 0100 p. 430	in the feed cable	1 per power pack	3	by customer	as locally required	acc. to local power supply regulations 3 Ph + N + PE*	feed cable to main switch	1 per power pack	4	by customer	each 10 m	equipotential bonding safety lead-out connection	corner pit floor/rearwall		5	by customer	1 unit	equipotential bonding safety compliant to the DIN EN 60204 standard	from the lead-out connection to the Parklift system	1 per Parklift	6	by customer	1 unit	marked main switch, lockable to prevent unauthorized switching on	above operating device	1 per power pack	7	by customer	10 m	PVC control cable with marked strands and protective conductor 5 x 1,5 ²	from main switch to hydraulic power pack	1 per power pack				
Item	Performance	Quantity	Designation	Position	Frequency																																																
1	by customer	1 unit	electric meter	in the feed cable																																																	
2	by customer	1 unit	fuse or automatic circuit breaker 3x16A slow blow acc. to DIN VDE 0100 p. 430	in the feed cable	1 per power pack																																																
3	by customer	as locally required	acc. to local power supply regulations 3 Ph + N + PE*	feed cable to main switch	1 per power pack																																																
4	by customer	each 10 m	equipotential bonding safety lead-out connection	corner pit floor/rearwall																																																	
5	by customer	1 unit	equipotential bonding safety compliant to the DIN EN 60204 standard	from the lead-out connection to the Parklift system	1 per Parklift																																																
6	by customer	1 unit	marked main switch, lockable to prevent unauthorized switching on	above operating device	1 per power pack																																																
7	by customer	10 m	PVC control cable with marked strands and protective conductor 5 x 1,5 ²	from main switch to hydraulic power pack	1 per power pack																																																

Statics and construction requirements-

The units to be fixed on the anchor points with heavy duty anchor bolts to a depth of approx. 10-12cm. Base plate thickness minimum 18cm.

Note :-

- 1) Quotation is for estimate purpose only.
- 2) GST as applicable shall be mentioned separately.
- 3) Rate is inclusive of supply / providing / fixing the item on site.

Executive Engineer (B)
PCNTDA, Akurdi, Pune-44